



Otay Water District, Public Services Division  
 2554 Sweetwater Springs Blvd  
 Spring Valley, CA 91978-2004

## METER REQUEST APPLICATION IRRIGATION

**Meter Rating:**

Size	GPM
3/4"	24
1"	40
1-1/2"	80
2"	128
3"	400
4"	800
6"	1,600
8"	2,720
10"	4,000

1. Are Property Taxes assessed on this parcel? Y/N

A water meter shall be sized to ensure that the maximum demand (in gallons per minute) will not exceed 80% of the manufacturer's recommended maximum flow rate, as shown in Section 27.03. In no case shall the water meter size be less than 3/4-inch.

Backflow Prevention Details are located at [www.sdwac.com](http://www.sdwac.com)

### OWNER INFORMATION

Company Name:

Contact Name:

Contact E-Mail Address:

Company Address:

City:

State:

ZIP Code:

Phone:

Fax:

Cellular:

**\*Who is financially responsible for payment of the monthly water bill?  
(circle one) OWNER                  APPLICANT**

### APPLICANT INFORMATION

Company Name:

Contact Name:

Contact E-Mail Address:

Company Address:

City:

State:

ZIP Code:

Phone:

Fax:

Cellular:

### PROJECT INFORMATION

Project Name:

Project Number:

Service Address:

City:

State:

ZIP Code:

POC:

Irr Sq. Ft.:

Station:

Lateral Size:

Meter Size:

POC:

Irr Sq. Ft.:

Station:

Lateral Size:

Meter Size:

POC:

Irr Sq. Ft.:

Station:

Lateral Size:

Meter Size:

Signature of Applicant:

Date: