



Otay Water District, Public Services Division
 2554 Sweetwater Springs Blvd
 Spring Valley, CA 91978-2004

METER REQUEST APPLICATION RESIDENTIAL

WATER FIXTURE UNIT COUNTS

Are Fire Sprinklers required for this construction: Y/N

Total Water Fixture Unit Counts for this construction: _____

✓ Include: Water Meter Data Card – Private (for residential projects)

A water meter shall be sized to ensure that the maximum demand (in gallons per minute) will not exceed 80% of the manufacturer's recommended maximum flow rate, as shown in Section 27.03. In no case shall the water meter size be less than ¾-inch.

Meter Rating:

Size	GPM
3/4"	24
1"	40
1-1/2"	80
2"	128
3"	400
4"	800
6"	1,600
8"	2,720
10"	4,000

OWNER INFORMATION

Company Name:

Contact Name:

Contact E-Mail Address:

Company Address:

City:

State:

ZIP Code:

Phone:

Fax:

Cellular:

***Who is financially responsible for payment of the monthly water bill?
(circle one) OWNER APPLICANT**

APPLICANT INFORMATION

Company Name:

Contact Name:

Contact E-Mail Address:

Company Address:

City:

State:

ZIP Code:

Phone:

Fax:

Cellular:

PROJECT INFORMATION

Project Name:

Project Number:

Project Address:

Project APN:

City:

State:

ZIP Code:

Lateral Size:

Meter Size:

Station No.:

Backflow Prevention Details are located at www.sdwas.com

Signature of Applicant:

Date: